

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Monitoring Requirements Not Met for Dubois Water Utilities, Inc.

Our water system recently violated a drinking water standard. Although this is not an emergency, as our customers, you have the right to know what happened, what you should do, and what we are doing to correct this situation.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meet EPA health standards. During November 2023 we did not complete all monitoring or testing for Total Coliform and therefore cannot be sure of the quality of our drinking water during that time.

What should I do?

There is nothing you need to do at this time.

What happened? What is being done?

Dubois Water Utilities, Inc. collected only 5 of the 10 required monthly samples that are tested for Total Coliform during the month of November 2023. Procedures have been put in place to assure all samples are collected as required.

For more information, please contact Superintendent Isaac Heeke at 812-678-5161 Extension #225

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by:
Dubois Water Utilities, Inc.

Water System ID#

IN5219002

Date distributed

1-11-2024